

**Planning** Castle Point Borough Council Kiln Road Thundersley Benfleet **SS7 1TF** 

Planning@castlepoint.gov.uk

Our Ref: 75942

Your Ref:

Date: 10 August 2021

Dear Sir/Madam,

Re: Town & Country Planning Act 1990

Planning Application No.: 21/0532/OUT

**Description: Planning Application for 68 residential units** 

Location: Land East of Manor Trading Estate Benfleet Essex SS7 4PS

Chief Fire Officer / Chief Executive

South East Group Service Delivery Point

Enquiries To: Joleen May, Fire Safety Officer

southeastgroupsdp@essex-fire.gov.uk

Rayleigh Weir Fire Station

500 Rayleigh Road

T: +44 (0)1376 576500

Benfleet

Essex SS7 3TR

Thank you for your letter dated 30/07/2021 enclosing drawings numbered Development Masterplan showing details of the above proposal.

The application has been considered and I draw your attention to the following comments:

## **Access**

Access for Fire Service purposes has been considered in accordance with the Essex Act1987 - Section 13 and appears to be acceptable subject to satisfactory compliance with Building Regulations B5.

More detailed observations on access and facilities for the Fire Service will be considered at Building Regulation consultation stage.

## **Building Regulations**

It is the responsibility of anyone carrying out building work to comply with the relevant requirements of the Building Regulations. Applicants can decide whether to apply to the Local Authority for Building Control or to appoint an Approved Inspector.

Local Authority Building Control will consult with the Essex Police, Fire and Crime Commissioner Fire and Rescue Authority (hereafter called "the Authority") in accordance with "Building Regulations and Fire Safety - Procedural Guidance".

Approved Inspectors will consult with the Authority in accordance with Regulation 12 of the Building (Approved Inspectors etc.) Regulations 2010 (as amended).

## **Water Supplies**

The architect or applicant is reminded that additional water supplies for firefighting may be necessary for this development. The architect or applicant is urged to contact the Water Technical Officer at Service Headquarters, telephone 01376-576344.

## **Sprinkler Systems**

"There is clear evidence that the installation of Automatic Water Suppression Systems (AWSS) can be effective in the rapid suppression of fires. Essex County Fire & Rescue Service (ECFRS) therefore uses every occasion to urge building owners and developers to consider the installation of AWSS. ECFRS are ideally placed to promote a better understanding of how fire protection measures can reduce the risk to life, business continuity and limit the impact of fire on the environment and to the local economy.

Even where not required under Building Regulations guidance, ECFRS would strongly recommend a risk-based approach to the inclusion of AWSS, which can substantially reduce the risk to life and of property loss. We also encourage developers to use them to allow design freedoms, where it can be demonstrated that there is an equivalent level of safety and that the functional requirements of the Regulations are met."

If you have any further queries, then please contact the above Officer quoting our reference number.

Yours faithfully

Joleen May **Protection**